

TOP VIEW

FRONT VIEW





RECOMMENDED SERVICE CLEARANCES TO ADJACENT CONSTRUCTION

SIDES	24(60.96)
FRONT	24(60.96)
REAR	24(60.96)
TOP	24(60.96)

NOTES:

- 1. ALL DIMENSIONS SHOWN ARE IN INCHES (CENTIMETERS)
- 2. STANDARD LOCATIONS FOR COMPONENTS/CONNECTIONS ARE ON THE RIGHT HAND SIDE. DOTTED LINES ARE ALTERNATE LOCATIONS.
- 3. WHEN USING ALTERNATE WATER CONNECTIONS, THE LEFT HAND AIR INTAKE CONNECTION CANNOT BE USED.
- 4. WHEN USING THE AERCO CONDENSATE NEUTRÁLIZER TANK, FOR PROPER CONDENSATE DRAINAGE, THE NEUTRALIZER TANK MUST BE INSTALLED IN A PIT <u>OR</u> THE BOILER AND THE AERCO CONDENSATE TRAP MUST BE ELEVATED HIGHER THAN 4" ABOVE THE FLOOR. SEE CONDENSATE TANK INSTRUCTIONS TID-0074 FOR DETAILS.



100 ORITANI DRIVE BLAUVELT, NY 10913 aerco.com

MODULEX EXT 321-1123/450-1100 MBH GAS FIRED BOILER INSTALLATION CLEARANCES

DWN.BY K.S. DATE 052013	
SCALE NTS	SD-A
PEY DATE KS 020717	SU-P

SD-A-967 |

REV.

C