



INSTALLATION CLEARANCES:

- 1) THIS APPLIANCE MAY BE INSTALLED ON COMBUSTIBLE FLOORING
- 2) MINIMUM CLEARANCES TO ADJACENT CONSTRUCTION ARE AS FOLLOWS:

LEFT & RIGHT SIDES: 24" FRONT: 24"

REAR: 24"

CEILING HIEGHT: 100"

- 3) THE INNER SIDE PANELS MUST BE REMOVED FROM BOTH UNITS FOR ZERO SIDE CLEARANCE INSTALLATIONS.
- 4) THE ZERO SIDE CLEARANCE OPTION CAN ONLY BE EMPLOYED IN TWO UNIT SETS.
- 5) THE ZERO SIDE CLEARANCE KIT (P/N# 58079-2) MUST BE INSTALLED

NOTE:

- 1. ALL DIMENSIONS SHOWN ARE IN INCHES (CENTIMETERS).
- 2. WHEN USING THE AERCO CONDENSATE NEUTRALIZER TANK, FOR PROPER CONDENSATE DRAINAGE, THE NEUTRALIZER TANK MUST BE INSTALLED IN A PIT <u>OR</u> THE BOILER AND THE AERCO CONDENSATE TRAP MUST BE ELEVATED 4" OR HIGHER ABOVE THE FLOOR. SEE CONDENSATE TANK INSTRUCTIONS TID-0074 FOR DETAILS.
- 3. CLEARANCE DIMENSIONS ARE MINIMUMS RECOMMENDED BY AERCO. LOCAL CODES AND AUTHORITIES SHOULD BE CONSULTED.

GAERCO.

A WAITS Brand

100 ORITANI DRIVE BLAUVELT, NY 10913 aerco.com

CFR 3000 MBH BOILER ZERO SIDE CLEARANCE DRAWING

DWN. BY <u>K.S.</u> DATE <u>061323</u>
SCALE _____ DATE _____ SD-A-1283 APPD. _____ DATE _____