

Certificate of Product Ratings

AHRI Certified Reference Number: 5760802 Date: 12/2/2013 †Status: Active

Product: Commercial Boiler Heating Equipment

Model Number: BMK 2500

Manufacturer: AERCO INTERNATIONAL, INC.

Trade/Brand name: AERCO

Rated as follows in accordance with Department of Energy (DOE) Boiler test procedures as published in the latest edition of the Code of Federal Regulations, 10 CFR Part 431 and subject to verification of rating accuracy by AHRI-sponsored, independent, third party testing:

Combustion Efficiency: 94.0 %
Thermal Efficiency: 93.5 %

The following data is for reference only and is not certified by AHRI:

Material: Stainless Steel

Location: Indoor

Fuel Type: Natural Gas

Input: 2500.0 MBTUH

Gross Output: 2337 MBTUH

Ignition Type: Intermittent/Electronic Ignition

Draft Type: Forced Draft

CO2: 9.0

Net Ratings - Water: 2032.00 MBTUH

DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at www.ahridirectory.org.

TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at www.ahridirectory.org, click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed below.

Air-Conditioning, Heating, and Refrigeration Institute

©2013 Air-Conditioning, Heating, and Refrigeration Institute

CERTIFICATE NO.: 130304679375086499

[†] Models with an 'Active' status are those that are currently in production. Models with a 'Discontinued' status are those that the manufacturer has elected to stop producing, yet stock is still available. Models with an 'Obsolete' status are those that the manufacturer is required to stop manufacturing due to an AHRI certification program test failure.

^{*} Ratings followed by an asterisk (*) indicate a voluntary rerate of previously published data, unless accompanied with a WAS, which indicates an involuntary rerate.