



NOTES:

- 1) RELAY CONTACTS ON CONNECTORS II, IV, and VI ARE RATED FOR 120VAC, 2 amps.
- 2) POWER PUMPS FROM INDEPENDENT CIRCUITS AND STARTERS.
- 3) FOR DOMESTIC WATER HEATING WIRING DIAGRAM, SEE DRAWING SD-A-699.
- 4) SEE MODULEX E8 CONTROLLER OPERATION & WIRING GUIDE GF-115-C FOR DETAILS OF ENABLE/DISABLE FUNCTION.

AERCO INTERNATIONAL, INC. Blauvelt, NY 10913		
MODULEX BOILER OUTDOOR RESET MODE WIRING DIAGRAM		
DWN. BY <u>CZ</u> DATE <u>092606</u> SCALE <u>NTS</u> APPD. _____ DATE _____	SD-A-697	REV. C