



FACTORY WIRING -----
 FIELD WIRING _____

- NOTES:
- 1) RELAY CONTACTS ON CONNECTORS II, IV, and VI ARE RATED FOR 120VAC, 2 amps.
 - 2) POWER PUMPS FROM INDEPENDENT CIRCUITS AND STARTERS.
 - 3) FOR OUTDOOR RESET MODE SPACE HEATING WIRING DIAGRAM, SEE DRAWING SD-A-697.
 - 4) FOR 0-10 VDC REMOTE SETPOINT MODE SPACE HEATING WIRING DIAGRAM, SEE DRAWING SD-A-698.

AERCO INTERNATIONAL, INC. Blauvelt, NY 10913		
MODULEX BOILER DOMESTIC WATER HEATING WIRING DIAGRAM		
DWN. BY <u>CZ</u> DATE <u>092606</u>	SCALE <u>NTS</u>	REV. <u>C</u>
APPD. _____ DATE _____	SD-A-699	