



NOTES:

- 1) WIRING TO BE SHIELDED TWISTED PAIR CABLE (BELDEN 9841 OR EQUIVALENT).
- 2) TERMINATE SHIELDS AT THE SOURCE ONLY, DO NOT CONNECT AT THE BOILERS.
- 3) ON THE BCM BOARD OF THE LAST BOILER ONLY:
 - POSITION THE JUMPER ON JP1 AS SHOWN.
 - A 1K OHM BIAS RESISTOR MAY BE REQUIRED ACROSS TERMINALS 2 AND 4 OF CONNECTOR Y2. CHECK WITH THE BUILDING AUTOMATION SYSTEM MANUFACTURER AND SEE MODULEX CONTROLS MANUAL GF-115-C.

Blauvelt, NY 10913		
RS485 COMMUNICATIONS FROM BUILDING AUTOMATION SYSTEM TO MODULEX		
DWN. BY <u>CZ</u> DATE <u>103008</u>	SCALE <u>NTS</u>	REV. <u>B</u>
APPD. _____ DATE _____	SD-A-727	