



- 1) THIS APPLIANCE MAY BE INSTALLED ON COMBUSTIBLE FLOORING  
 2) MINIMUM CLEARANCES TO ADJACENT CONSTRUCTION ARE AS FOLLOWS:  
 LEFT & RIGHT SIDES: 24"  
 FRONT: 24"  
 REAR: 24"  
 CEILING HIEGHT: 100"

- NOTE:  
 1. ALL DIMENSIONS SHOWN ARE IN INCHES (CENTIMETERS).  
 2. THE ZERO SIDE CLEARANCE OPTION CAN ONLY BE EMPLOYED IN TWO UNIT SETS. DOOR PANEL REMOVAL NOT REQUIRED FOR ZERO SIDE CLEARANCE.  
 3. WHEN USING THE AERCO CONDENSATE NEUTRALIZER TANK, FOR PROPER CONDENSATE DRAINAGE, THE NEUTRALIZER TANK MUST BE INSTALLED IN A PIT OR THE BOILER AND THE AERCO CONDENSATE TRAP MUST BE ELEVATED 4" OR HIGHER ABOVE THE FLOOR. SEE CONDENSATE TANK INSTRUCTIONS TID-0074 FOR DETAILS.  
 4. SECONDARY INLET ONLY AVAILABLE ON BENCHMARK® PLATINUM SERIES UNITS.  
 5. CLEARANCE DIMENSIONS ARE MINIMUMS RECOMMENDED BY AERCO. LOCAL CODES AND AUTHORITIES SHOULD BE CONSULTED.

		100 ORITANI DRIVE BLAUVELT, NY 10913 aerco.com	
<b>BENCHMARK 1500-2000 MBH          GAS FIRED BOILER ZERO SIDE          CLEARANCE DRAWING</b>			
DWN. BY <u>K.S.</u> DATE <u>11/04/13</u>		REV <b>B</b>	
SCALE _____ APPD. _____ DATE _____		<b>SD-A-996</b>	