


INSTALLATION CLEARANCES:

- 1) THIS APPLIANCE MAY BE INSTALLED ON COMBUSTIBLE FLOORING
- 2) MINIMUM CLEARANCES TO ADJACENT CONSTRUCTION ARE AS FOLLOWS:
  - LEFT & RIGHT SIDES: 24"
  - FRONT: 24"
  - REAR: 24"
  - CEILING HEIGHT: 100"

NOTES:

1. ALL DIMENSIONS SHOWN ARE IN INCHES (CENTIMETERS).
2. WHEN USING THE CONDENSATE NEUTRALIZER TANK, FOR PROPER CONDENSATE DRAINAGE, THE NEUTRALIZER TANK MUST BE INSTALLED IN A PIT OR THE HEATER AND THE CONDENSATE TRAP MUST BE ELEVATED 4" OR HIGHER ABOVE THE FLOOR. SEE CONDENSATE TANK INSTRUCTIONS OMM-0175 FOR DETAILS.
3. CLEARANCE DIMENSIONS ARE MINIMUMS RECOMMENDED BY AERCO. LOCAL CODES AND AUTHORITIES SHOULD BE CONSULTED.

AERCO RESERVES THE RIGHT TO MODIFY WATER HEATER DIMENSIONS WITHOUT PRIOR NOTICE

	100 ORITANI DRIVE, BLAUVELT, NY 10913 aerco.com
INNOVATION 1600/2000 GAS FIRED WATER HEATER SINGLE & ZERO SIDE CLEARANCE UNITS DIMENSIONAL DRAWING	
DWN. BY <u>K.S.</u> DATE <u>032425</u>	REV. <u>A</u>
SCALE <u>NTS</u>	SD-A-1366
REV. BY _____ DATE _____	