



INSTALLATION CLEARANCES:

- 1) THIS APPLIANCE MAY BE INSTALLED ON COMBUSTIBLE FLOORING
- 2) MINIMUM CLEARANCES TO ADJACENT CONSTRUCTION ARE AS FOLLOWS:
 LEFT & RIGHT SIDES: 24"
 FRONT: 24"
 REAR: 24"
 CEILING HEIGHT: 100"
- 3) REMOVAL OF IN-BETWEEN SIDE PANELS REQUIRED ONLY WHEN USING 14" SIDE AIR INLET TO SUPPLY COMBUSTION AIR TO BOTH UNITS.

- NOTES:**
1. ALL DIMENSIONS SHOWN ARE IN INCHES (CENTIMETERS).
 2. WHEN USING THE AERCO CONDENSATE NEUTRALIZER TANK, FOR PROPER CONDENSATE DRAINAGE, THE NEUTRALIZER TANK MUST BE INSTALLED IN A PIT OR THE BOILER AND THE AERCO CONDENSATE TRAP MUST BE ELEVATED 4" OR HIGHER ABOVE THE FLOOR. SEE CONDENSATE TANK INSTRUCTIONS TID-0074 FOR DETAILS.
 3. SECONDARY INLET ONLY AVAILABLE ON BENCHMARK® PLATINUM SERIES UNITS.
 4. CLEARANCE DIMENSIONS ARE MINIMUMS RECOMMENDED BY AERCO. LOCAL CODES AND AUTHORITIES SHOULD BE CONSULTED.

AERCO
A WATTS Brand

100 ORITANI DRIVE BLAUVELT, NY 10913
aerco.com

BENCHMARK® 4000 MBH NATURAL GAS
BOILER ZERO SIDE CLEARANCE
DIMENSIONAL DRAWING

DWN. BY <u>K.S.</u> DATE <u>092319</u>	REV. <u>B</u>
SCALE <u> </u> SIZE <u>A</u>	AP-A-1191
CHKD. <u> </u> APPD. <u> </u>	
REV. DATE <u>K.S. 102419</u>	