



INSTALLATION CLEARANCES:

- 1) THIS APPLIANCE MAY BE INSTALLED ON COMBUSTIBLE FLOORING
- 2) MINIMUM CLEARANCES TO ADJACENT CONSTRUCTION ARE AS FOLLOWS:
 LEFT & RIGHT SIDES: 24"
 FRONT: 24"
 REAR: 24"
 CEILING HEIGHT: 100"

NOTE:

1. ALL DIMENSIONS SHOWN ARE IN INCHES (CENTIMETERS).
2. WHEN USING THE AERCO CONDENSATE NEUTRALIZER TANK, FOR PROPER CONDENSATE DRAINAGE, THE NEUTRALIZER TANK MUST BE INSTALLED IN A PIT OR THE BOILER AND THE AERCO CONDENSATE TRAP MUST BE ELEVATED 4" OR HIGHER ABOVE THE FLOOR. SEE CONDENSATE TANK INSTRUCTIONS TID-0074 FOR DETAILS.
3. SECONDARY INLET ONLY AVAILABLE ON BENCHMARK PLATINUM SERIES UNITS.
4. CLEARANCE DIMENSIONS ARE MINIMUMS RECOMMENDED BY AERCO. LOCAL CODES AND AUTHORITIES SHOULD BE CONSULTED.



100 ORITANI DRIVE BLAUVELT, NY 10913
aerco.com

BENCHMARK® 4000-5000N MBH
NATURAL GAS BOILER SINGLE UNIT
CLEARANCE DIMENSIONAL DRAWING

DWN. BY K.S. DATE 102419
 SCALE _____ SIZE A
 CHKD. _____ APPD. _____
 REV. DATE K.S. 041520

AP-A-1195

REV.
B