



INSTALLATION CLEARANCES:

- 1) THIS APPLIANCE MAY BE INSTALLED ON COMBUSTIBLE FLOORING
- 2) MINIMUM CLEARANCES TO ADJACENT CONSTRUCTION ARE AS FOLLOWS:
 LEFT & RIGHT SIDES: 24"
 FRONT: 24"
 REAR: 24"
 CEILING HEIGHT: 100"
- 3) REMOVAL OF IN-BETWEEN SIDE PANELS REQUIRED ONLY WHEN USING 14" SIDE AIR INLET TO SUPPLY COMBUSTION AIR TO BOTH UNITS.

- NOTES:
1. ALL DIMENSIONS SHOWN ARE IN INCHES (CENTIMETERS).
 2. WHEN USING THE AERCO CONDENSATE NEUTRALIZER TANK, FOR PROPER CONDENSATE DRAINAGE, THE NEUTRALIZER TANK MUST BE INSTALLED IN A PIT OR THE BOILER AND THE AERCO CONDENSATE TRAP MUST BE ELEVATED 4" OR HIGHER ABOVE THE FLOOR. SEE CONDENSATE TANK INSTRUCTIONS TID-0074 FOR DETAILS.
 3. SECONDARY INLET ONLY AVAILABLE ON BENCHMARK® PLATINUM SERIES UNITS.
 4. CLEARANCE DIMENSIONS ARE MINIMUMS RECOMMENDED BY AERCO. LOCAL CODES AND AUTHORITIES SHOULD BE CONSULTED.
 5. THE ZERO SIDE CLEARANCE OPTION CAN ONLY BE EMPLOYED IN TWO UNIT SETS.

 <small>A WATTS Brand</small>	100 ORITANI DRIVE BLAUVELT, NY 10913 aerco.com
BENCHMARK® 4000/5000N MBH NATURAL GAS BOILER ZERO SIDE CLEARANCE DIMENSIONAL DRAWING	
DWN. BY <u>K.S.</u> DATE <u>092319</u> SCALE _____ SIZE <u>A</u> CHKD. _____ APPD. _____ REV. DATE <u>K.S.</u> <u>031220</u>	SD-A-1191
AERCO RESERVES THE RIGHT TO MODIFY BOILER DIMENSIONS WITHOUT PRIOR NOTICE	

REV. C